

# Lincoln/Haney Engineering Associates, Inc.

Structural Engineering Consultants

Michael A. Cunningham, P.E., LEED AP  
Peter L. Lincoln, P.E.  
William D. Haney, P.E.

## ADDENDUM #2

**DATE:** July 27, 2016

**PROJECT:** Structural Improvements & Re-roofing  
at Connor Consolidated School  
1581 Van Buren Road  
Connor Township, Maine

**OWNER:** Maine Department of Education  
5<sup>th</sup> Floor Cross State Office Building  
23 State House Station  
Augusta, ME 04333-0077

**BID DATE:** July 29, 2016

---

The contract documents dated July 11, 2016 are modified in accordance with this addendum as follows:

<b>DESCRIPTION</b>	<u>Relating to Specifications:</u> none
	<u>Relating to Drawings:</u> none
	<u>Responses to Questions:</u> Question: For Alternate #1, how high should the curb height be extended for the new skylight? Response: Extend the curb as needed to provide a minimum vertical leg of the flashing of 8".
<b>ATTACHMENTS</b>	none